



DESCRIPTION OF LOAD	VDB-1 (LIGHTING)	VDB-2 (EXTERNAL LIGHTING)	APFC PANEL 35kVAR	PUMP PANEL-I	PUMP PANEL-II
CONNECTED LOAD (kW)	3	3	--	30.0	30.625
POWER CABLE (mm <sup>2</sup> ) Al.	25	25	25	70	70
No. OF CORES	4	4	4	3.5	3.5
No. OF RUNS	1	1	1	1	1
LENGTH IN METERS	40	10	10	--	--
EARTHING (GI)	10	10	--	25x3	25x3

**FOR TENDER PURPOSE ONLY**

A												<b>KITCO Ltd.</b> <small>(Estd. in 1972 by IDBI &amp; Govt. of Kerala)          PUTHIYA ROAD - NH BYPASS, KOCHI - 28</small>	

T:\2013\586 NG (TVM,TRCHR,TRP SKD)\04 JIMMY GEORGE STADIUM, TVM\ELECTRICAL\TENDER PURPOSE\SLD.dwg - Jan. 03, 2013

SL.No.	PARTICULARS	INITIAL	DATE	UNIT:	SCALE:	DRG NO:	SHEET NO:	REV.	DATE:
	<b>REVISION</b>			mm.	N.T.S	DP 586 DRG EL 04 002	1 OF 2		03.01.13

This drawing is the property of KITCO Ltd. and is to be used only for the purpose for which it was lent and must not be in any way detrimental to the interest of the company and is subject to return on demand