

Dear Sir,

With reference to the Pre Bid meeting please find the points given below:

1. Kindly clarify if the drains have to be made of RCC & using TMT bars. - **The drains shall be of RCC if the depth of drain is more than 30 cm.**
2. Who will be responsible for the supply and fixing of Net posts & nets. - **Will be arranged separately.**
3. Total area of courts to be confirmed as tender document mentions only (23.8m*10.97m) - **The total area for 4 courts will be 2690 sqm.**
4. Is ITF classification certificate a must for equivalent products as mentioned in the tender be accepted without ITF classification certificate.- **ITF Classification certificate is a must.**
5. We had requested the qualification criteria to be increased to a minimum of completion of 20 courts and completion certificates from reputed organisations to be provided.- **Qualification criteria shall be as specified in tender**
6. Synthetic Acrylic Surface specification to be considered and changed to:
 - One Layer Acrylic Resurfacer
 - Four Layers Cushion
 - Three Layers Colour
 - Line Marking - **The Layers shall be as specified in tender** (Please see the Corrigendum)
7. Please do consider changing the synthetic acrylic surface thickness of 4.5mm to 5.0mm thickness which has been mentioned as thickness is an acrylic court is not measured and instead remove thickness and ask for each bidder to mention the consumption quantity of material.- **The thickness of acrylic surface shall be 6mm. Also the bidder has to specify the consumption quantity of material.**

Sd/-

Chief Engineer