

**CORRIGENDUM NO.1**


**CORRIGENDUM NO.1 TO THE TENDER NO.53/2014-15/NGS DATED 29.11.2014 FOR SUPPLY, INSTALLATION OF FIRE FIGHTING EQUIPMENTS IN THE GAMES VILLAGE, MENAMKULAM, THIRUVANANTHAPURAM**

**Dated 09.12.2014**

Due to the revision in the technical specification for the Fire Extinguisher (Item No.2) the New BOQ is uploaded.

The item No.2 mentioned in the Annexure 3 shall be changed and attached herewith.

Other terms and conditions of the tender will remain unchanged.

  
Chief Engineer

National Games Secretariat

## ANNEXURE 3

### TECHNICAL SPECIFICATONS

#### **2. MAP 90 Fire Extinguisher(09 Kg)**

- IS Specification IS:15683
- Jet range (in mtrs)- <6
- Discharge Time (in sec)- 25-30
- Seal of approval-ISI
- Must be wall mounted
- The powder must be Mono Ammonium Phosphate
- ISI CE certification NABL test certificate must be attached